

THE CORPORATION OF THE TOWNSHIP OF HORTON

**Public Meeting**

**Community Center Retrofit and System Upgrades, 80% Design  
Information Session  
July 18<sup>th</sup>, 2023  
4:00 p.m.**

There was a Public Meeting held on July 18<sup>th</sup>, 2023. Present was Mayor David Bennett, Deputy Mayor Tom Webster, Councillor Glen Campbell, Councillor Doug Humphries, and Councillor Daina Proctor. Staff present was Hope Dillabough, CAO/Clerk, Nathalie Moore, Treasurer, Adam Knapp, Public Works Manager and Nichole Dubeau, Executive Assistant-Recording Secretary.

**1. CALL TO ORDER**

Mayor David Bennett called the Public Meeting to Order at 4:02 pm.

**2. DECLARATION OF PECUNIARY INTEREST**

There was no declaration of pecuniary interest.

**3. COMMUNITY CENTRE RETROFIT AND SYSTEM UPGRADES, 80% DESIGN**

Ed Schultz, Project Manager, Architectural Engineer and Patrick Scission, Electrical Technologist from Jp2g Consultants Inc. were present.

Mr. Schultz and Mr. Scission reviewed the design of the upgrades. Highlighted were accessible showers and washrooms in the changerooms, a ramp to access the rink and changerooms, mechanical and electrical upgrades to the Community Centre, electric vehicle charging stations, solar panels, and lighting upgrades.

**4. PUBLIC MEMBERS COMMENTS/QUESTIONS**

There was no public attendance and no comments or questions.

**5. COUNCIL MEMBERS COMMENTS/QUESTIONS**

Councillor Campbell questioned if the panel was large enough to handle the upgrades as well as the generator. Mr. Scission stated that the existing panel would be able to handle the upgrades and the generator is also existing and individual breakers are selected to be run when the power is out. Councillor Webster questioned if the septic system needs to be upgraded or enlarged to accommodate the new features. Public Works Manager Adam Knapp stated the holding tank will have to be replaced.

**6. ADJOURNMENT**

Mayor Bennett adjourned the public meeting at 4:20 pm.

---

MAYOR David M. Bennett

---

CAO/CLERK Hope Dillabough